



Product Service

# CERTIFICATE

No. Z2 011102 0505 Rev. 00

**Holder of Certificate:** Heinrich Kopp GmbH  
Alzenauer Str. 68  
63796 Kahl  
GERMANY

**Certification Mark:**



**Product:** Crystalline Silicon Terrestrial Photovoltaic (PV) Modules  
Mono-Crystalline Silicon Photovoltaic Module

The product was tested on a voluntary basis and complies with the essential requirements. The certification mark shown above can be affixed on the product. It is not permitted to alter the certification mark in any way. In addition, the certification holder must not transfer the certificate to third parties. This certificate is valid until the listed date, unless it is cancelled earlier. All applicable requirements of the testing and certification regulations of TÜV SÜD Group have to be complied. For details see: [www.tuvsud.com/ps-cert](http://www.tuvsud.com/ps-cert)

**Test report no.:** 701262110301-00

**Valid until:** 2026-07-14

**Date,** 2021-11-18

( Zhulin Zhang )



Product Service

# CERTIFICATE

No. Z2 011102 0505 Rev. 00

## Model(s):

KOPP-J1. PV-Mod.HZ- xxx Wp, xxx=365 to 390  
KOPP-J1. PV-Mod.HZ- xxx Wp, xxx=395 to 415  
KOPP-J2. PV-Mod.HZ- xxx Wp, xxx=390 to 410  
KOPP-J2. PV-Mod.HZ- xxx Wp, xxx=465 to 500  
KOPP-J2. PV-Mod.HZ- xxx Wp, xxx=505 to 545  
KOPP-J1. PV-Mod.HZ- xxx Wp, xxx=485 to 505  
KOPP-J1. PV-Mod.HZ- xxx Wp, xxx=525 to 550  
xxx stands for rated output power at STC

## Parameters:

Construction:	Framed with Junction box, Cable and Connectors.
Test Laboratory:	Yangzhou Opto-Electrical Products Testing Institute No. 10 West Kaifa Road, Yangzhou 225009 Jiangsu, P. R. China
Safety Class:	Class II
Maximum System Voltage:	1500 V DC
Fire Safety Class:	Class C according to UL790.

## Tested according to:

IEC 61215-1:2016  
EN 61215-1:2016  
IEC 61215-1-1:2016  
EN 61215-1-1:2016  
IEC 61215-2:2016  
EN 61215-2:2017  
IEC 61730-1:2016  
EN IEC 61730-1:2018  
EN IEC 61730-1:2018/AC:2018-06  
IEC 61730-2:2016  
EN IEC 61730-2:2018  
EN IEC 61730-2:2018/AC:2018-06