



Product Service

CERTIFICATE

No. Z2 011102 0507 Rev. 00

Holder of Certificate: **Heinrich Kopp GmbH**
Alzenauer Str. 68
63796 Kahl
GERMANY

Certification Mark:



Product: **Crystalline Silicon Terrestrial Photovoltaic (PV) Modules**
Mono-Crystalline Silicon Photovoltaic Module

The product was tested on a voluntary basis and complies with the essential requirements. The certification mark shown above can be affixed on the product. It is not permitted to alter the certification mark in any way. In addition, the certification holder must not transfer the certificate to third parties. This certificate is valid until the listed date, unless it is cancelled earlier. All applicable requirements of the testing and certification regulations of TÜV SÜD Group have to be complied. For details see: www.tuvsud.com/ps-cert

Test report no.: 701262110301-01

Valid until: 2028-03-08

Date, 2023-03-10

(Zhulin Zhang)



CERTIFICATE

No. Z2 011102 0507 Rev. 00

Model(s):

KOPP-J1. PV-Mod.HZ- xxx Wp,xxx=365 to 390
 KOPP-J1. PV-Mod.HZ- xxx Wp,xxx=395 to 415
 KOPP-J2. PV-Mod.HZ- xxx Wp,xxx=390 to 410
 KOPP-J2. PV-Mod.HZ- xxx Wp,xxx=465 to 500
 KOPP-J2. PV-Mod.HZ- xxx Wp,xxx=505 to 545
 KOPP-J1. PV-Mod.HZ- xxx Wp,xxx=485 to 505
 KOPP-J1. PV-Mod.HZ- xxx Wp,xxx=525 to 550
 KOPP-J1.B.PV-Mod.HZ- xxx Wp,xxx=395 to 405
 KOPP-J1.PV-Mod.HZ- xxx Wp,xxx=400 to 420
 KOPP-J1.PV-Mod.HZ- xxx Wp,xxx=535 to 560
 KOPP-J2. PV-Mod.HZ- xxx Wp,xxx=405 to 420
 KOPP-J2. PV-Mod.HZ- xxx Wp,xxx=540 to 560
 KOPP-J2. PV-Mod.HZ- xxx Wp,xxx=540 to 585
 xxx is standing for rated output power at STC

Parameters:

Construction:	Framed or Frameless, with Junction box, Cable and Connectors.
Test Laboratory:	Yangzhou Opto-Electrical Products Testing Institute No. 10 West Kaifa Road, Yangzhou 225009 Jiangsu, P. R. China
Safety Class:	Class II
Maximum System Voltage:	1500 V DC or 1000 V DC
Fire Safety Class:	Class C or Class A according to UL790.

Tested according to:

IEC 61215-1:2016
 EN 61215-1:2016
 IEC 61215-1-1:2016
 EN 61215-1-1:2016
 IEC 61215-2:2016
 EN 61215-2:2017
 IEC 61730-1:2016
 EN IEC 61730-1:2018
 EN IEC 61730-1:2018/AC:2018-06
 IEC 61730-2:2016
 EN IEC 61730-2:2018
 EN IEC 61730-2:2018/AC:2018-06