

# ATTESTATION OF CONFORMITY

Issued to: Heinrich Kopp GmbH  
Alzenauer Straße 68 63796 Kahl am Main, Germany

For the product: PV Grid-tied Inverter

Trade name: 

Type/Model: KOPP.Kuara 3.0-2-S, KOPP.Kuara 3.6-2-S, KOPP.Kuara 4.6-2-S,  
KOPP.Kuara 5.0-2-S, KOPP.Kuara 5.3-2-S, KOPP.Kuara 6.0-2-S

Ratings: See Annex

Manufactured by: Heinrich Kopp GmbH  
Alzenauer Straße 68 63796 Kahl am Main, Germany

Requirements: EN 61000-6-1:2007;  
EN 61000-6-2:2005;  
EN 61000-6-3:2007+ A1:2011+ AC:2012;  
EN 61000-6-4:2007+ A1:2011

This Attestation is granted on account of an examination by DEKRA, the results of which are laid down in a confidential file no. 2250939R-PV-CE-P01V01

This Attestation implies that the examined types are in accordance with the standards designated under the Electromagnetic compatibility directive 2014/30/EU.

The examination has been carried out on one single specimen or several specimens of the product, submitted by the manufacturer. The Attestation does not include an assessment of the manufacturer's production. Conformity of his production with the specimen tested by DEKRA is not the responsibility of DEKRA.

The CE marking may be affixed on the product if all relevant and effective EC directives are complied with.

Arnhem, 13 June 2022

Number: 6132641.01AOC

DEKRA Testing and Certification (Shanghai) Ltd.



Cliff Lin  
Certification Manager

© Integral publication of this attestation and adjoining reports is allowed

Page 1 of 2



# Annex

---

Document no.: 6132641.01AOC

## **Ratings of the test product:**

### **KOPP.Kuara 3.0-2-S:**

PV input: Max. 600 Vdc, MPPT voltage range: 80-550 Vdc, max 14 A / 14 A, I<sub>sc</sub> PV: 18 A / 18 A  
Output: 230 Vac, 50/60 Hz, rated apparent power 3000W, max apparent power 3300 VA, rated 13.0 A, max 14.3 A

### **KOPP.Kuara 3.6-2-S:**

PV input: Max. 600 Vdc, MPPT voltage range: 80-550 Vdc, max 14 A / 14 A, I<sub>sc</sub> PV: 18 A / 18 A  
Output: 230 Vac, 50/60 Hz, rated apparent power 3600 W, max apparent power 3960 VA/ 3600 VA (G98), rated 15.7 A, max 17.2 A / 15.7 A (G98)

### **KOPP.Kuara 4.6-2-S:**

PV input: Max. 600 Vdc, MPPT voltage range: 80-550 Vdc, max 14 A / 14 A, I<sub>sc</sub> PV: 18 A / 18 A  
Output: 230 Vac, 50/60 Hz, rated apparent power 4600 W, max apparent power 5060 VA/ 4600VA (German), rated 20.0 A, max 22 A / 20 A (German)

### **KOPP.Kuara 5.0-2-S:**

PV input: Max. 600 Vdc, MPPT voltage range: 80-550 Vdc, max 14 A / 14 A, I<sub>sc</sub> PV: 18 A / 18 A  
Output: 230 Vac, 50/60 Hz, rated apparent power 5000 W, max apparent power 5500 VA/ 5000 VA (Australia and Belgium), rated 21.7 A, max 23,9 A/ 21.7 A (Australia and Belgium)

### **KOPP.Kuara 5.3-2-S:**

PV input: Max. 600 Vdc, MPPT voltage range: 80-550 Vdc, max 14 A / 14 A, I<sub>sc</sub> PV: 18 A / 18 A  
Output: 230 Vac, 50/60 Hz, rated apparent power 5300 W, max apparent power 5830 VA, rated 23.0 A, max 25.3 A

### **KOPP.Kuara 6.0-2-S:**

PV input: Max. 600 Vdc, MPPT voltage range: 80-550 Vdc, max 14 A / 14 A, I<sub>sc</sub> PV: 18 A / 18 A  
Output: 230 Vac, 50/60 Hz, rated apparent power 6000 W, max apparent power 6000 VA, rated 26.1 A, max 26.1 A

---

End